



Hvad er der i kassen?

- LAGUR behandlingsrør
- LAGUR elektronikstyring
- Adapter for schukostik



1. Installation af behandlingsrør

- Husk at installering altid skal være **EFTER** vandmåleren.
- LAGUR behandlingsrør kan montres vertikalt samt horisontalt (og alt dér i mellem).
- Gennemstrømningsretningen er valgfri.

Sådan gør du...


Under montering hold **ALTID** nøglen på det blanke stykke af røret.



2. Tilslut styreenheden

VIGTIGT ved montering af elektronikboks:
Skal tilsluttes jordstik.
Enheden er standardmonteret med schukostik.





CERTIFIKAT

CERTIFICATE



**GODKENDT
TIL DRIKKEVAND**

Dette certifikat er udstedt i henhold til bekendtgørelse nr. 1007 af 29. juni 2016 om markedsføring og salg af byggevarer i kontakt med drikkevand. Certifikatet giver godkendelsesindehaveren rettighed til at markedsføre og sælge nedenstående byggevarer i Danmark og til at mærke byggevarer med "Godkendt til drikkevand"-mærkningen.

This certificate is issued according to Executive Order no. 1007 of 29 June 2016 on the placement on the market and sale of building components that come into contact with drinking water. The certificate gives the approval holder the rights to market and sell the following building component in Denmark and to mark the building component with the "Godkendt til drikkevand" marking.

GODKENDELSE NR. / APPROVAL NO.:

05/00024

UDSTEDT / DATE OF ISSUE:

23-10-2023

UDLØBER / EXPIRY DATE:

22-10-2028

GODKENDELSESINDEHAVER / APPROVAL HOLDER:

**CVR 36070641
LAGUR A/S
Attrupvej 4
8550 Ryomgård
Danmark**

BYGGEVARE / BUILDING COMPONENT:

Lagur Vandbehandler 100100 VB



BETINGELSER FOR GODKENDELSE:

De nærmere betingelser og vilkår for godkendelsen er fastsat i bekendtgørelse nr. 1007 af 29. juni 2016 om markedsføring og salg af byggevarer i kontakt med drikkevand. Endvidere henvises til godkendelsesbrev af 23-10-2023 om godkendelse af ovennævnte byggevarer i kontakt med drikkevand og eventuelle senere ændringer til godkendelsesbrevet fremsendt til godkendelsesindehaver. Markedsføring og salg af byggevarer efter nærværende godkendelse omfatter de versioner af byggevarer, der er opført i bilaget, og den variantproduktion, der er angivet i bilaget.

CONDITIONS OF APPROVAL:

The detailed terms and conditions of approval are laid down in Executive Order no. 1007 of 29 June 2016 on the placement on the market and sale of building components in contact with drinking water. See also the approval letter of 23-10-2023 on the approval of the above-mentioned building component in contact with drinking water, and any subsequent amendments to the approval letter submitted to the approval holder. Marketing and sale of the building component under this approval include the versions of the building component listed in the Annex and the "on-demand" production specified in the Annex.

CERTIFIKATET ER UDSTEDT AF:

THE CERTIFICATE IS ISSUED BY:

Social- og Boligstyrelsen

Danish Authority of Social Services and Housing
Carsten Niebuhrs Gade 43
1577 København V
Mail: GDV@bpst.dk
Web: www.bpst.dk

København, den 23-10-2023